



Thermal Performance Indicators (TPI) Monitoring and Reporting Enhanced Using PEPSE


Wen Wang

Performance & Testing Department
Ontario Power Generation
25-January-17



OPG - Who and Where We Are

- Ontario's clean power producer
- Approx. 17,000 MW generating capacity
 - 65 hydro, 3 thermal (including 2 biomass), 2 nuclear stations
 - 2 co-owned gas-fired stations
- 2 nuclear stations leased to a private generator
- Produce about 50 per cent of Ontario's electricity
- About 9,200 regular employees
- Over \$44 billion in assets
- Moderate overall price of power





Clean, Reliable, Low-Cost

- Province's clean energy provider – more than 99% free of smog and greenhouse gas emissions.
- Produce majority of power homes, hospitals, schools, businesses rely on every day.
- Provide consumers with lower cost power than other generators.
- Our profit goes back to the province.
- Investing hundreds of millions in clean and renewable power.
- Successful closure of our coal stations represents North America's largest single climate change initiative.
- Strive to ensure efficiency, value for money.



The Company We are Today

- Our history includes more than 100 years of operation.
- Commitment to public, environmental and employee safety.
- Values set out in a Code of Conduct – safety, integrity, excellence, people and citizenship.
- Building long-term mutually beneficial relationships with Indigenous communities.
- Enjoy strong relations with site communities.
- Focused on continuous improvement and development in project management and operational excellence.
- Environmental Management System registered to ISO 14001 standard.



Nuclear Operations - Darlington

- One of the top-performing nuclear stations in the world.
- Four-unit station with a total capacity of 3,512 MW.
- Serves about 20 per cent of Ontario's electricity needs – or a city of two million people.
- In 2015, OPG received a 10 year operating licence for Darlington from the CNSC– the longest ever granted to a Canadian nuclear power plant.
- OPG Nuclear is rate regulated through a transparent, public process.





Nuclear Operations - Pickering

- Six operating CANDU reactors.
- Total output of 3,100 MW, enough to serve a city of 1.5 million people.
- Recognized across the industry for safety.
- In 2015, Pickering supplied about 14 per cent of Ontario's power while achieving its highest level of reliability.
- In 2013, Pickering's operating licence was renewed for five more years of operation.





Introduction – TPI Program

- TPIs including Thermal Performance Indicator (TPI), Turbine Cycle Efficiency (TCX), the Condenser Vacuum Efficiency (CVE), Thermal Power Error (TPE), and Non-Productive Load (NPL) are monitored and reported routinely (three times a week).
- As a Scientific, Engineering and Safety Analysis (SESA) software for engineering support, it should be SESA certified. National standard CSA N286.7 and company procedures applies.
- Independent TPI calculations are executed to cross check the results.
- Two methods: Curve-method; PEPSE-method
- Performance analysis and MW accounting will be performance engineer's focuses.
- TPI Program Automation and historical performance database are required. All features including PEPSE OLE automation are integrated together using convenient Excel spreadsheet.



Key TPI Calculations

- Thermal Performance Indicator (TPI)

$$\text{TPI} = \frac{\text{Actual overall unit efficiency}}{\text{Design overall unit efficiency}}$$

- Turbine Cycle Efficiency (TCX) and MWe Loss

$$\text{TCX} = \frac{\text{Actual turbine cycle efficiency}}{\text{Design turbine cycle efficiency}}$$

- Condenser Vacuum Efficiency (CVE) and MWe Loss

$$\text{CVE} = \frac{P_{\text{atm}} - P_{\text{cnd}}}{P_{\text{atm}} - P_{\text{design}}}$$

- Thermal Power Error (TPE) and MWe Loss

$$\text{TPE} = \frac{\text{Measured Reactor Power (by DCCs)} - \text{Actual Reactor Power (Calorimetric Heat Balance)}}{\text{Actual Reactor Power (Calorimetric Heat Balance)}}$$

$$\text{MWe Loss} = (\text{TPE} \times \text{Reference Reactor Power}) \times \text{Reference Unit Overall Efficiency} / 10000$$

- Non-Productive Load (NPL) and MWe Loss

$$\text{MWe Loss} = (\text{Actual NPL prorated to 100\%} - \text{Reference NPL}) \times \text{Actual Turbine Cycle Efficiency} / 100$$



Data Collection – DCC Data

- Calorimetric test
 - ✓ Controlled test (as steady as possible) performed three times a week
- DCC
 - ✓ Dependent on the Digital Control Computer (DCC) system to retrieve required data (around a hundred measurement points)
 - ✓ Data validation
- Interfaces
 - ✓ Input the Dates corresponding to the calorimetric test. DCC data will be updated for the time corresponding to the test.



Data Collection – Manual Inputs

- Correction factors
 - ✓ The total feedwater flow
 - Deaerator Mass and Energy Balance (DAMEB) tests carried out every four years
 - Ultrasonic flow measurements annually
 - ✓ Feedwater temperatures, reheater drains flow and temperature
 - Precision measurements using calibrated instruments.
 - ✓ The above values are used in deriving the boiler thermal power, which is an input into the PEPSE model.
- Corrections applied to DCC measurements when suspect measurements cause the PEPSE models to non-converge




Curve Method – Thermal Performance Curves

- Generator Terminal Output (GTO) vs net boiler power
- GTO vs CCW inlet temperature at 100% FP
- GTO vs condenser pressure at 100% FP
- Condenser pressure vs CCW inlet temperature at 100% FP
- A general polynomial relationship to represent the curves
 - ✓ $Y = A7*X^7 + A6*X^6 + A5*X^5 + A4*X^4 + A3*X^3 + A2*X^2 + A1*X^1 + A0$
 - ▶ Where Y = calculated result of the function
 - ▶ X = function variable
 - ▶ A0 to A7 = coefficients




PEPSE Method – Simplified Turbine Cycle





PEPSE Method – PEPSE Model





PEPSE Method – PEPSE Model Sets

- Five cases to simulate different plant conditions with different boundary conditions

Case #	Case Description	Purpose
1	Performance Mode	<ul style="list-style-type: none"> - Simulate the design turbine cycle using PEPSE Performance mode - Based on the design heat balance .
2	Design Mode	<ul style="list-style-type: none"> - Simulate the design turbine cycle using PEPSE Design mode.. - Tune unit performance to actual reference of output of 932.6 MWe, lake water temperature of 12 °C, condenser pressure of 5.04 kPa, reactor power at 100% FP
3	Design Mode (TCX)	<ul style="list-style-type: none"> - Simulate of the design turbine cycle using the Design Mode with the exception of the condensers, which is in the performance mode, at the defined station measured condenser pressure. - Use the simulated output in the TCX calculation
4	Design Mode (TPI)	<ul style="list-style-type: none"> - Simulate the design performance of the turbine cycle. - Use the simulated output in the TPI and CVE calculations
5	Performance	<ul style="list-style-type: none"> - Simulate actual performance of the major components at conditions including process steam consumption and equipment out of service through setting up a series of controls



PEPSE Method -

Object Linking and Embedding (OLE) Automation

- The use of PEPSE is automated through the spreadsheet program for the routine calculations.
- The PEPSE five cases used for TPIs calculations are automated.
- The automation controller (Microsoft Excel) uses a scripting language Visual Basic for Applications (VBA)
 - ✓ Collect data
 - ✓ Send data to a PEPSE model
 - ✓ Run model calculations
 - ✓ Show model results
 - ✓ Save data and results to database
 - ✓ Use steam tables




User Interfaces

The execution time for the software is expected to be typically in the order of a few minutes, for reporting occurring once a week.

Darlington GS - Thermal Performance Indicators

Enhanced Using PEPSE



Version: 001

System Root Directory: C:\ThermalPerformance\

Backup Database

1. Collect Data (create .prn)

2. TPI & MW Accounting

Unit 1	Unit 2	Unit 3	Unit 4
<input checked="" type="checkbox"/> 1X	<input type="checkbox"/> 2X	<input checked="" type="checkbox"/> 3X	<input type="checkbox"/> 4X
<input type="checkbox"/> 1Y	<input checked="" type="checkbox"/> 2Y	<input type="checkbox"/> 3Y	<input checked="" type="checkbox"/> 4Y
<input type="button" value="Select All"/>		<input type="button" value="Deselect All"/>	

3. PEPSE Analysis (All Units)

RP Criteria (%)	95		
Unit 1	Unit 2	Unit 3	Unit 4

4. Copy Results to Database

5. Weekly TPI Report

Start	05 / 21 / 2015 00:00
End	05 / 27 / 2015 23:59
RP Criteria (%)	97.6

6. TPI Report - 12 Month Rolling

Date (Month-Year)	Dec-15
RP Criteria (%)	97.6

7. TPI Report - Monthly

Month	Nov-15
RP Criteria	97.6

8. TPI Monitoring Analysis

Trend Year	2014
RP Criteria	99

Quick Navigation Group

EPR 12mth	REPORTwk	CCW-t1	TPICAL	P1	P3	PEPSE	1X	2X	3X	4X
EPRmth	CF	HBAL	OTHERCAL	P2	P4	TPI REPORT	1Y	2Y	3Y	4Y



Execution of PEPSE Analysis

The execution time for the PEPSE analysis for all for units is about 40 seconds.

Model:	OWSG TFS V8H1MEX	Job:	PAJOB	Result:	PLRES		
Unit 4 PEPSE Model Analysis	NORM TERMINATION			8/31/2016 1:07			
Items	Unit	DCC Curve Method	Case 3 Actual BP (TC/Heat)	PEPSE Case 4 Actual CCS233	Case 5 Actual	DCC vs PEPSE Int. %	Equipment Operation Comments
PEPSE Analysis Complete							
Actual GTD	MWt	100.00	100.00				
Adjusted Gross Generator Output	MWt	100.00	100.00				
Feed Temp HX5A	Deg C	110.00	110.00				
Feed Temp HX5B	Deg C	110.00	110.00				
Feed Temp HX5	Deg C	110.00	110.00				
Feed Flow - Total	kg/s	100.00	100.00				
Reheater Flow - Total	kg/s	100.00	100.00				
Boiler Blow Off Flow - Total	kg/s	1.00	1.00				
IJFW Flow - Total	kg/s	1.00	1.00				
Sum of FW_2nd RH Drain IJFW	kg/s	100.00	100.00				
Main Steam Flow	kg/s	100.00	100.00				
Measured Cond Press	kPa	100.00	100.00				
Ideal Cond Press	kPa	100.00	100.00				
CGW inlet (Jaks) temperature	Deg C	100.00	100.00				
Total Calorimetric Boiler Power	MWth	100.00	100.00				
% Boiler Power	%	100.00	100.00				
Calorimetric Reactor Power %	%	100.00	100.00				
FINCH based reactor power	%	100.00	100.00				
Calorimetric - FINCH power	%	100.00	100.00				
TCX	%	100.00	100.00			100.00	
CVE	%	100.00	100.00			100.00	
TPI	%	100.00	100.00			100.00	
Condensate Flow	kg/s	100.00	100.00			100.00	
Condenser Cleanliness Factor		1.00	1.00			1.00	
Main Steam Press	kPa	100.00	100.00			100.00	
MSR Drain Flow - Total	kg/s	100.00	100.00			100.00	
HX5 Drain Flow - Total	kg/s	100.00	100.00			100.00	
HP Inlet Press	kPa	100.00	100.00			100.00	
HP Outlet Press	kPa	100.00	100.00			100.00	

Model Termination Status

Unit 1: Normal Termination
 Unit 2: Normal Termination
 Unit 3: Normal Termination
 Unit 4: Normal Termination

Choose a Unit or the main screen to activate.

Unit 1 Unit 2 Unit 3 Unit 4

---TPI---

Execution of PEPSE Analysis



Results and Data Storage, Trend Plot

- Spreadsheet databases
 - ✓ Calculated results and input data
 - Current database - save all the data of the most recent five years
 - Historical database – save all the years data
- Trend plots – monitoring, analysis
 - ✓ All raw data
 - ✓ Calculated results
 - ✓ The X-axis & Y-axis
 - a time or any other data points of the database.



Output Report

- **TPI Weekly Report - the key output of the software**
 - ✓ A summary of the key thermal performance indicators
 - ✓ Megawatt loss accounting,
 - ✓ Condenser ball cleaning updates
 - ✓ Actions assigned to each unit to recover the lost megawatts.
- **Colour-coded grading for the calculated TPI, TCX, CVE, TPE, NPL**


Indicator	Green Excellent	White Nominal	Yellow Marginal	Red Unsatisfactory
TPI	$TPI \geq 99.5\%$	$99.0\% \leq TPI < 99.5\%$	$98.5\% \leq TPI < 99.0\%$	$TPI < 98.5\%$
TCX	$TCX \geq 99.75\%$	$99.5\% \leq TCX < 99.75\%$	$99.0\% \leq TCX < 99.5\%$	$TCX < 99.0\%$
CVE	$CVE \geq 99.75\%$	$99.5\% \leq CVE < 99.75\%$	$99.0\% \leq CVE < 99.5\%$	$CVE < 99.0\%$
TPE	$-0.25\% \leq TPE \leq +0.25\%$	$-0.50\% \leq TPE \leq -0.25\%$ Or $+0.25\% < TPE \leq +0.50\%$	$-1.0\% \leq TPE < -0.50\%$ Or $+0.50\% < TPE \leq +1.0\%$	$TPE < -1.0\%$ Or $TPE > +1.0\%$
NPL	$NPL \leq +0.1\%$	$0.1\% < NPL \leq +0.3\%$	$0.3\% < NPL \leq 0.5\%$	$TPE > 0.5\%$

- [TPI Report Example](#)



PEPSE Application

PEPSE Expected MWE @Actual CCW t1 and actual BP-Case 5





Software Attributes

- **Functionality**
 - ✓ Executed on Standard Windows7 Office Computer
- **Reliability**
 - ✓ 100% reliable when station LAN is available
- **Usability**
 - ✓ Require minor training
- **Maintainability**
 - ✓ Performed in the Microsoft Excel interface as well as VBA coding
- **Portability**
 - ✓ Require the station Windows 7 LAN environment.



Main Interfaces

- System Interfaces
 - ✓ DCC system, PEPSE software
- User Interfaces
 - ✓ Manual inputs including correction factors, dates, etc
- Hardware Interfaces
 - ✓ Minimum standard issue Windows 7 Office Computer
- Software Interfaces
 - ✓ Microsoft Excel embedded with VBA as well as PEPSE model



Thanks!